

PREVENTATIVE MAINTENANCE

Mitigate Against Air Conditioning System Malfunction



2021

CONTACT US

(868) 2-SCOTTS (272-6887) Phone

(868)470 1347 Mobile

admin@scottsglobal.com

www.scottsglobal.com



UNDERSTANDING PREVENTATIVE MAINTENANCE

Preventive maintenance is undeniably a critical component to any maintenance strategy. It is key to lowering maintenance costs, reducing equipment downtime, improving asset lifespan and efficiency, and increasing workplace safety.

In Trinidad and Tobago, 80% of companies have experienced an unexpected outage in the last three years because of poor maintenance strategies. Having a clear, well defined, and consistent maintenance plan is crucial for the long-term success of any business.

Preventive maintenance is crucial to any business looking to reduce maintenance costs and the number of reactive maintenance issues it addresses annually.

Preventative maintenance allows you to stay ahead of issues before they arise.

What Is Preventive Maintenance?

Preventive maintenance involves taking the necessary precautions and actions to prevent accidents or equipment failures from occurring before they happen. Performing equipment inspections, cleaning and lubricating essential equipment parts, are examples of preventive maintenance.

The goal of preventive maintenance is to prevent equipment failure before it occurs, and to reduce the risk of accidents. Ultimately, taking certain precautions to ensure minimal risk to your air conditioning equipment means that you can focus on improving your operations, instead of having to constantly repair broken equipment.

Preventative maintenance is not reactive (i.e. a response to a problem, malfunctioning equipment, technology, etc.).

Types of Preventive Maintenance

Here are some of the most common different types of preventative maintenance:

Time-based maintenance

It is essential to create a monthly or annual maintenance schedule that complies with manufacturer recommendations for inspecting and cleaning your air conditioning equipment. Even outside of these recommendations, you should keep in mind that the most essential equipment to your business should be checked regularly to ensure the best possible operations.

Usage-based maintenance

If your business uses certain air conditioning equipment every single day, it's a good idea to track usage (i.e. operating hours). This is referred to as usage-based maintenance.

If certain rooms are used more frequently than others or if certain areas of the building are subjected to harsher environmental factors, then these areas may require more frequent maintenance.

Predictive maintenance

Predictive maintenance relies on sensors to capture information about equipment (i.e. temperature sensors, or vibration sensors). Predictive maintenance entails monitoring the condition of essential machinery to track performance, and to detect possible defects that could result in a system crash.

Prescriptive maintenance

Similar to the patterns that predictive maintenance analyzes, prescriptive maintenance uses advanced analytics, machine learning, and artificial intelligence to generate predictions about maintenance, and also act on them. What does this mean? Basically, prescriptive maintenance makes recommendations to improve system operations, and also follows up to produce a work orders and oversees the entire process.

Benefits of Preventive Maintenance

Of course, one of the most obvious benefit of implementing preventive maintenance is that you're more likely to stay ahead of problems before they occur.

- Preventive maintenance will **decrease business downtime and closures** due to unexpected equipment failures;
- Preventive maintenance will **increase equipment life expectancy**, so you'll spend fewer dollars in the long run.
- Preventive maintenance will ensure all equipment and employees **work only during scheduled hours**, eliminating the need for paying overtime due to unexpected machinery breakdowns, etc.
- Preventive maintenance will **significantly reduce safety risks** for employees and customers, thereby reducing the costly risk of lawsuits and workers' comp.
- Preventive maintenance means **less energy consumption** for your assets and equipment due to high levels of operational efficiency, which will reduce your utility bills.



These are only a few of the specific benefits that accompany regular preventive maintenance. Even if you are a small retail business and don't have large air conditioning equipment, preventive maintenance as it applies to your business will go a long way toward reducing costly accidents and damage.





Split Type Air Condition Servicing Methodology

Evaporator Section

1. Ensure instructions to execute relative to unit location and quantities are documented and disseminated to respective supervisors by Administration.
2. Client is informed that “Service” level service will be executed on the day so that occupants, if any are notified accordingly.
3. Technicians are to secure and sign for all necessary tools and equipment needed to execute service.
4. The following must be done when performing an “Special” level service:
 - I. Before switching off unit, its operation must be observed and recoded on checklist.
 - II. Air handler/fan coil power supply should be then turned off and Lock-Out Tag-Out procedure followed.
 - III. Air filters removed and cleaned using pressurized water only.
5. Panels to access the coil and motor/blower assembly removed.
6. Apply concentrated coil cleaning solution to both side of coil and allow to soak to ensure proper penetration. This process will be repeated as many times as needed.
7. Belts, blower bearings, motor bearings, pulleys and blower-wheels inspected and its condition recorded.
8. Blower/motor assembly disassembled in the case of fan coils.
9. The Fan motor and all electrical components that may be in the path of direct water or mist during service must be made waterproof by cover with an appropriate material.
10. Coil and blower-wheel must be pressure washed and care taken to limit water accumulation in blower housing.
11. Damaged coil fins combed

12. Belts must be immediately replaced whenever required.
13. Clean, Inspect and record condition of drain pan and unit panels.
14. Use vacuum and or pressurized water to clean/clear condensate drain line.
15. Components, filters and panels reassembled and unit is restarted.
16. Operating motor amperage must be taken recorded and all finding submitted to office.
17. Care must be taken to ensure the air handler room and surrounding areas are left clean.
18. Repaint/anti corrosive treating shall be executed on a needs basis on all units.

Condensing Unit

1. Panels to access the coil and motor assembly removed.
2. The Fan motor and all electrical components that may be in the path of direct water or mist during service must be made waterproof by cover with an appropriate material.
3. Inspect motor/s for bearing integrity and abnormal noises
4. Visually inspect condenser for oil residue
5. Visually inspect condensing unit for loose or broken parts
6. On system start-up check operation for proper operation.
7. Inspect electrical section for tidiness.
19. Coil must be pressure washed.
20. Damaged coil fins combed.
21. Repaint/anti corrosive treating shall be executed on a needs basis on all units.



A Solutions Company

Design • Service • Installation

General Servicing Checklist

| | | | |
|--------------------------|--|-------------------|--------------|
| Customer Name : | | | |
| Address: | | | |
| Job Ticket No. | | Date: | Time: |
| Job Description: | | | |
| Model Number: | | Serial No: | |
| Location of Unit: | | | |
| | | | |

| EVAPORATOR SECTION | YES | NO | CONDENSING UNIT | YES | NO |
|----------------------------------------------------|-----|----|----------------------------------------------------------|-----|----|
| Performance checked before service | | | Performance checked before service | | |
| Thermostat battery and accuracy good | | | Coil cleaned and free of fouling | | |
| Filter in place and cleaned | | | Fins combing needed | | |
| Unit internal insulation ok | | | Fan bearing need lubrication | | |
| Blower rotation correct | | | Fan blade/s in place and rotation correct | | |
| Blower wheel rusted | | | Electrical connections cleaned and tight | | |
| Coil cleaned and free any fouling | | | Panel missing screws | | |
| Secondary pan in good and piped | | | Refrigerant lines secured and properly insulated | | |
| Pulley and flywheel wear checked | | | Panel Painting required | | |
| Check & lubricate motor bearings | | | Moisture observed in sight glass | | |
| Blower bearing checked and lubricated | | | Unusual noise or vibration | | |
| Air flow checked and is acceptable | | | Discarded AC related parts nearby | | |
| Evaporator fins need combing | | | Fan propeller or bearings noisy | | |
| Condensate water flowing freely | | | Checked unit mounting brackets, ensured securely mounted | | |
| Condensate Drain trapped | | | Compressor Oil level OK (if applicable) | | |
| Unit's ducting connection good | | | Fan guards in place and screwed down | | |
| AHU room clean | | | Hot air recycling | | |
| Unit Panel missing screws/ clean | | | System Operating parameters checked and documented | | |
| Base or Panel Painting required | | | Oil/refrigerant stains observed | | |
| Unusual noise or vibration | | | Line insulation deteriorated | | |
| Thermostat secured and properly set | | | Fan capacitor Checked OK | | |
| Oil/refrigerant stains observed | | | | | |
| Liquid line filter rusted | | | | | |
| Belts good | | | | | |
| Electric connections tightened and clean | | | | | |
| Fan capacitor checked OK | | | | | |
| Electrical wiring neat and tidy | | | | | |
| 10ft of supply, return duct and return grill clean | | | | | |

Observations _____

RECOMMENDATIONS

Technician _____ Supervisor _____
 Technician signature _____ Supervisor signature _____

SAMPLE EVALUATION REPORT

The following are excerpts from an evaluation report that had been done for a company with an existing maintenance program using reactive maintenance. Several issues were found that would eventually lead to system malfunction.

SAMPLE



TECHNICAL REPORT

Project Information: Assessment of the air conditioning systems

Location:

Date: March 23rd 2021

Client:

Equipment Information:

| Type | Make | System Tonnage | Quantity |
|------------------|---------|----------------|----------|
| Direct Expansion | Carrier | 30 Ton | 2 |
| Direct Expansion | Carrier | 20 Ton | 3 |

Note: One system comprises of an air handling unit and either one or 2 matching condensing units



Summary of Findings

The Physical inspection of all major components of the listed air conditioning systems was performed to evaluate wear and performance factors. A determination was made on the overall condition of the systems and the risk to sustainable operation. Energy consumption considerations were also factored as part of the report. The systems evaluated are Carrier's high performance machines designed to offer superior cooling and sustainable operation for several years if maintained properly. However, based on the findings noted within the report it is evident that these systems are not being inspected regularly for defects and performance nor are they being serviced within a frequency that is in keeping with industry best practices.

Several critical defects were observed that place systems at risk for failure and/or because of these defects systems are forced to consume more energy than it normally would during operation. Further, some components have been allowed to deteriorate so significantly that complete replacement is the only resolve in this regard. Additionally, systems were also found to have exceedingly dirty air ducts, faulty protective devices as well as missing parts further adding to the state of disrepair.

The following report identifies the risk and the urgency in which action should be taken to prevent multiple system failures.

It should be also noted that elements in the risk category of Yellow and Red should be given attention.



System 1 (North)



| | |
|--------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------|
| <p>Air Handler Identification</p> <p>Make - CARRIER Capacity - 30Tons</p> | <p>Model number =</p> <p>Serial number =</p> |
| <p>Condensing Unit Identification</p> <p>Make - CARRIER</p> <p>Capacity - 15 Tons x 2</p> | <p>Cond 1 - Model number = Serial number =</p> <p>Cond 2 = Model Serial number =</p> |



Risk Key



| | | |
|----------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|
| <p>Good Condition - No action Required at this time</p> | <p>Medium Risk - Repair or Replacement Action should be considered in the short term. System</p> | <p>High Risk - Urgent Action Required. System or Component Failure Imminent</p> |
|----------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|

| | | |
|--|-----------------------------------------|--|
| | or component performance Compromised | |
|--|-----------------------------------------|--|

Air Handler

| Component | Observation | Risk | Recommendation | Supporting Image |
|-----------------|---------------------------------------------------------|------|-------------------------------------------------------------------------|--------------------------------------------------------------------------------------|
| Evaporator Coil | 50% deterioration. Heat transfer surface compromised | | Air Handler would be the most cost effective solution in the short term |  |
| Blower Wheels | Metal starting to deteriorate | | Short term blower wheel replacement required |  |
| Blower shaft | Ungreased and heavily corroded | | Shaft need to be treated and re-greased | |
| Bearings | Fair condition | | | NA |
| Belts | Fair Condition | NA | | NA |
| Motor Pulley | Fair Condition | NA | | NA |
| Fly Wheel | Fair Condition | NA | | NA |

| | | | | |
|------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|---------------------------------------------------------------|---------------------------------------------------------------------------------------|
| Fan Motor | <p>Failing Bearings</p> <p>This can result in motor failure</p> | | <p>Motor bearings should be replaced urgently</p> | |
| Line Insulation | <p>Missing Insulation</p> <p>This can impact performance.</p> <p>Expansion valve bulb uninsulated – this will cause the valve to perform erratically and risk compressor failure</p> | | <p>Expansion valve bulb and suction line needs insulation</p> |  |
| Refrigerant pipe | Fair Condition | | NA | NA |
| Thermostat | Fair Condition | | NA | |
| Ducting | <p>Broken wall compromising return duct opening.</p> | | <p>Wall should be repaired and supported.</p> |  |

| | | | |
|----------------------------|-----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|--------------------------------------------------------------------------------------|
| | <p>Ducting is extremely dirty. This significantly affects the indoor air quality of the space and can lead human respiratory issues</p> | <p>Urgent Duct cleaning needed</p> |  |
| <p>Panel Insulation</p> | <p>Insulation deteriorated and disconnected from panel</p> | <p>Insulation should be replaced ASAP</p> |  |
| <p>Secondary drain pan</p> | <p>Signification deteriorated</p> | <p>Replace drain pan</p> | |

A Solutions Company

Design • Service • Installation

Secondary
Drain Pan

Significant fouling
and corrosion –

This is a health and
indoor air quality
concern






Drain pan servicing urgently
required



Condensing Unit

| Component | Observation | Risk | Recommendation | Supporting Image |
|-----------|-------------|------|----------------|------------------|
|-----------|-------------|------|----------------|------------------|

| | | | | |
|--------------|-------------------------|----------------------------|----|--------------------------------------------------------------------------------------|
| Bearings | | | |  |
| Belts | Faulty Belt | Replace fan belt ASAP | NA | |
| Motor Pulley | Defective Pulley | Replace motor pulley | |  |
| Fly Wheel | Fair Condition | NA | NA | |
| Fan Motor | Motor bearing defective | Replace motor bearing ASAP | NA | |


| | | | | |
|----------------------|------------------------------------------------------------------------------|--|-----------------------------------------------|-------------------------------------------------------------------------------------|
| Cond 2 | 2 fan motors and fan blades missing - Condenser coil also deteriorated | | Entire condensing unit should be replaced |  |
| Fan Motor Cond 1 | 1 of 2 fan motor defective | | Replace entire condensing | |
| Fan Blade Cond 1 | Fair condition | | NA | NA |
| Control Panel Cond 1 | Faulty voltage monitor | | Replace voltage monitor when replacing system | |
| Compressor Cond 1 | Operating at risk due to defective condenser coil and fan motor | | Replace entire condensing | NA |
| Base | Fair condition | | NA | NA |
| Refrigerant Level | Inconclusive- due to defective condenser coil and fan motor | | Replace entire condensing | NA |



A Solutions Company

Design • Service • Installation

Line
Insulation

| | | | |
|---------------------------------------------|--|----------------------------------------------------------|-------------------------------------------------------------------------------------|
| Significant line insulation deterioration – | | Replace insulation when replacing entire condensing unit |  |
| | | | |

System 5

| | |
|---------------------------------------|-------------------|
| Air Handler Identification | Model number = |
| Make - CARRIER | C Serial number = |
| Condensing Unit Identification | |



A Solutions Company

Design • Service • Installation



| | |
|--------------------|---------------------------|
| Make – CARRIER | Cond 1 – Model number = - |
| Capacity – 20 Tons | Serial number = |



Risk Key

| | | |
|---------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------|
| | | |
| Good Condition – No action Required at this time | Medium Risk – Repair or Replacement Action should be considered in the short term. System performance Compromised | High Risk - Urgent Action Required. System or Component Failure Imminent |

Air Handler

| Component | Observation | Risk | Recommendation | Supporting Image |
|-----------|-------------|------|----------------|------------------|
|-----------|-------------|------|----------------|------------------|

| | | | | |
|-----------------------|---------------------------------------------------------------------------------------------------------------------------------------------------|--|---------------------------------------|--------------------------------------------------------------------------------------|
| Evaporator Coil | <p>40% Deterioration -</p> <p>This negatively impact system performance and increases energy consumption - ,</p> <p>Compressor placed at risk</p> | | Replace air handler in the short term |  |
| Blower Wheels | Fair condition | | NA | NA |
| Blower shaft Bearings | <p>Fair Condition</p> <p>Defective blower bearings -</p> <p>Risk of blower failure</p> | | Replace bearing ASAP |  |
| Belts | Defective belt | | Replace belt ASAP | NA |

| | | | | |
|------------------|----------------------------------------------------------|--|------------------------------------------------|---------------------------------------------------------------------------------------|
| Motor Pulley | Defective pulley – Risk of belt and motor failure | | Replace motor pulley ASAP |  |
| Fly Wheel | Fair Condition | | NA | NA |
| Fan Motor | Defective bearings This can lead to motor failure | | NA | NA |
| Line Insulation | Fair condition | | NA | NA |
| Refrigerant pipe | Multiple refrigerant leaks observed | | Pressure test and repair all refrigerant leaks |  |
| Thermostat | Fair condition | | NA | NA |



Report Verified by: Rudson Scott. PMP
Managing Director /Service Engineer
SCOTTS GLOBAL Limited



Mission Statement

Our mission is to provide quality services in the realm of installation, repair, maintenance and design of Ventilation, and Air Conditioning (VAC) equipment in the residential, commercial and the industrial markets.

We have set the following objectives to accomplish our goals:

- Ensure that our procedures adhere to international standards and best practices
- Maintain the highest level of design and engineering practices
- Establish and cultivate a training programs with technical staff to ensure quality installation and services are sustained.
- Hire, develop, and retain employees who are committed to our growth and customer satisfaction.

At SCOTTSGLOBAL Limited (SGL) our customers are our life-line. Our strong values and quality workmanship helped make us leaders in the VAC industry. We are a company you can rely on, much like your own family. Every customer is a priority to SGL. We look forward to working with you soon. To all of our old friends and new ones.... Welcome to our Family!



Our 7 Principles of Business

- Contribution to Society
- Fairness and Honesty
- Cooperation and Team Spirit
- Untiring Effort for Improvement
- Courtesy & Humility
- Adaptability
- Gratitude

The SCOTTS GLOBAL VISION

We will be recognized as the most professional team of VAC products and services while providing reliable service and installation. We will also lead the way toward more efficient and effective methods and procedures.

Value Statement

SGL is a company that **will...**

- Provide 100% customer satisfaction
- Be open and honest
- Work together as a team
- Change for the better of ourselves, customers, and industry
- Always think of new ways to promote growth and better serve our clientele